

VOC Content Test Certificate

Friday June 18th, 2010

Manufacturer: MITEQ (4/273, Wickham Road Moorabbin Victoria 3189)

Sample Description: MITEQ Sealer 102 as water-proofing treatment for masonry

Date Tested: June 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Data: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

| | |
|---|--|
| Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11 | Penetrating Sealer 102 |
| Architectural Sealant 250 grams per Litre | <1 grams per Litre as VOC content per material |
| Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13 | Penetrating Sealer 102 |
| Architectural Sealant 250 grams per Litre | <1 grams per Litre as VOC content per material |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1006-01